

IEC**IECEE**

®

TM

Ref. Certif. No.

HU-003767

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product	Surge Protective Device for PV application
Name and address of the applicant	WENZHOU LEEYEE ELECTRIC CO., LTD. No. 1, Xingye Road, Dagang, Beibaixiang Town, Yueqing, 325603 Zhejiang, P.R. China
Name and address of the manufacturer	WENZHOU LEEYEE ELECTRIC CO., LTD. No. 1, Xingye Road, Dagang, Beibaixiang Town, Yueqing, 325603 Zhejiang, P.R. China
Name and address of the factory	WENZHOU LEEYEE ELECTRIC CO., LTD. No. 1, Xingye Road, Dagang, Beibaixiang Town, Yueqing, 325603 Zhejiang, P.R. China
Ratings and principal characteristics	Ucpv: 1000 V DC; In: 20 kA; Imax: 40 kA; Iscpv: 10 A Iimp: 6.25 kA; Up: 3.6 kV(+/-, +/PE, -/PE); indoor, Itotal: 40 kA(8/20 μs), 12.5 kA(10/350 μs) IP20; one port; -40 °C to +70 °C; Class I + Class II
Trademark (if any)	LEEYEE
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	LY1-C40PV
Additional information (if necessary may also be reported on page 2)	Detailed information refer to test report CN22RULB 001
A sample of the product was tested and found to be in conformity with	IEC 61643-31:2018
As shown in the Test Report Ref. No. which forms part of this Certificate	CN22RULB 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com

Date: 2022-01-24

Signature: Wencai Zhang