

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.* Blatt *Sheet*
R 50539472 0001

Ihr Zeichen *Client Reference* Unser Zeichen *Our Reference* Ausstellungsdatum *Date of Issue*
S.F.Q. 01-YangYongM-CN22QXXW 001 10.04.2022 (day/mo/yr)

Genehmigungsinhaber *License Holder*

WENZHOU LEEYEE ELECTRIC CO., LTD.
No. 1, Xingye Road, Dagang,
Beibaixiang Town, Yueqing,
325603 Zhejiang
P.R. China

Fertigungsstätte *Manufacturing Plant*

WENZHOU LEEYEE ELECTRIC CO., LTD.
No. 1, Xingye Road, Dagang,
Beibaixiang Town, Yueqing,
325603 Zhejiang
P.R. China

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*

EN 61643-31:2019
IEC 61643-31:2018

**Zertifiziertes Produkt (Geräteidentifikation)
*Certified Product (Product Identification)***

**Lizenzentgelte - Einheit
*License Fee - Unit***

Surge Protector (Surge Protective Device for PV application)

Type Designation : LY1-C40PV/2S, LY1-C40PV/2 (LEEYEE) 6
Ucpv : 600 V DC (+/- to PE)
Up : 2.2 kV
Iimp(10/350) : 6.25 kA
In : 20 kA
Iscpv : 10 A
Imax : 40 kA
Type of SPD : Type 1 + Type 2
Itotal : 40 kA(8/20); 12.5 kA(10/350)
Location : Indoor
Temperature : Extended range



6

ANLAGE (Appendix): 1.0

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

Zertifizierungsstelle

Zhao Xinhua

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

http://www.tuv.com/safety E-mail: markcheck@tuv.com
Fax: +49 221 806-3935

TÜV Rheinland (China) Ltd.
Member of TÜV Rheinland Group



WENZHOU LEEYEE ELECTRIC CO., LTD.
Mr. Sun Funqin General Manager
GM office
No. 1, Xingye Road, Dagang,
Beibaixiang Town, Yueqing,
325603 Zhejiang
P.R. China

Date : 11.04.2022
Our ref. : YangYongM 01
Your ref.: S.F.Q.

Ref : R TÜV-Mark Approval

Type of Equipment : Surge Protective Device for PV application
Model Designation : See Certificate
Certificate No. : R 50539472 0001
Report No. : CN22QXXW 001

Dear Mr. Sun Funqin,

The above specified technical equipment has been tested and found to be in accordance with the relevant requirements.

Enclosed you will find the certificate of approval.

If cancellation of the certificate is submitted by November 15 in a given year, no fee will be charged for the following year.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

Please contact our office for approval of your new products.

With kind regards,

Certification Body

Zhao Xinhua

cc: WENZHOU LEEYEE ELECTRIC CO., LTD.

Enclosure

证书的详细资料请登录<https://www.certipedia.com>查阅, 或拨打我司客服热线 800 999 3668/400 883 1300 咨询

TÜV Rheinland (China) Ltd.
Room 301, 3F and Room 1203, 12F,
Building 4, No. 15, Ronghua South Road,
Beijing Economic-Technological
Development Area, Beijing
www.chn.tuv.com

莱茵检测认证服务(中国)有限公司
北京市北京经济技术开发区
荣华南路15号院4号楼3层301室
12层1203室
邮编: 100176
www.chn.tuv.com

Tel: 86 10 8524 2222
Fax: 86 10 8524 2200
Hotline: 400 883 1300
800 999 3668
GC Service mailbox: service-gc@tuv.com

电话: 86 10 8524 2222
传真: 86 10 8524 2200
热线: 400 883 1300
800 999 3668
大中华区服务邮箱: service-gc@tuv.com