

# Zertifikat

# Certificate



Zertifikat Nr. *Certificate No.*  
R 50488349

Blatt *Sheet*  
0002

Ihr Zeichen <i>Client Reference</i>	Unser Zeichen <i>Our Reference</i>	Ausstellungsdatum	<i>Date of Issue</i>
S.F.Q.	01-Wuchale-CN20PX06 001	04.12.2020	(day/mo/yr)

**Genehmigungsinhaber *License Holder***  
WENZHOU LEEYEE ELECTRIC CO., LTD.  
No. 1, Xingye Road, Dagang,  
Beibaixiang Town, Yueqing,  
325603 Zhejiang  
P.R. China

**Fertigungsstätte *Manufacturing Plant***  
WENZHOU LEEYEE ELECTRIC CO., LTD.  
No. 1, Xingye Road, Dagang,  
Beibaixiang Town, Yueqing,  
325603 Zhejiang  
P.R. China

## Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*  
EN 61643-11:2012+A11

**Zertifiziertes Produkt (Geräteidentifikation)**  
*Certified Product (Product Identification)*

**Lizenzentgelte - Einheit**  
*License Fee - Unit*

Surge Protector (Surge Protective Device)

Continuation from page 0001

Up	: 1.5 kV
Iscrr	: 25 kA
In	: 20 kA
Imax	: 40 kA
Type of SPD	: Type 2
Location	: Indoor
Temperature	: -40°C to 70°C



ANLAGE (Appendix): 1.0

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.  
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

**Zertifizierungsstelle**

**Zhao Xinhua**

**TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg**

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com  
Fax: +49 221 806-3935 http://www.tuv.com/safety